

**CONFIDENTIAL**

23 AUG 1982

MEMORANDUM FOR: Special Security Center

ATTENTION:  

25X1X1

FROM: 

25X1

Chief, Domestic Security Branch

SUBJECT: Physical Security Inspection of Room 212 Key Building

REFERENCE: Memo for C/DSB from SSC, dtd 27 Jul 82; Same Subject

1. On 18 August 1982, a representative of this Branch conducted a physical security inspection of room 212, Key Building to assure that the area meets security standards for the storage of Sensitive Compartmented Information (SCI).

25X1

2. The inspection revealed that the room requires the following modifications:

a. Viewports on the primary and secondary doors should be covered with 1/8-inch sheet steel welded to the inside of the doors.

b. Install a combination rate-of-rise, fixed temperature automatic fire detection system in the area to provide complete area coverage. The installation is to conform to the applicable provisions of the National Fire Codes, No. 72D, Standards for Proprietary Protective Signalling Systems. The installation should conform with existing systems located elsewhere in Key Building.

25X1

3.  FBIS Support Officer advised that his Office would take immediate steps to alleviate security deficiencies.

25X1

25X1

4. Any questions regarding this inspection can be referred to Chief, Domestic Security Branch,

25X1

25X1

25X1

**CONFIDENTIAL**